




Technical Requirements:

1. Valve body shall be clean, no dirt and all components shall be fixed in right position;
2. During the assembly, the valve shall be no serious impact and damage to appearance quality;
3. Under the condition of continuous water supply after the pipeline is drained into the air, the ball inside shall automatically close valve and no leakage and eternal deformation caused when make the leakage test under pressure of 2.4MPa and keep for 1 to 2min.

4	DLR02-098-02	Valve cap	1	HPb58-3A		
3		O ring	1	NBR		Ø 30×3
2	DLR02-051-02	Rubber ball	1	NBR		
1	DLR02-098-01	Valve body	1	HPb58-3A		
No.	Drawing No.	Name	Q'TY	Material	Weighth	Remark
				1" Air Release Valve Material. assembly	DWG No. DLR02-098-00	
					Customer or Manu. DWG No. HV001A	
					W.T. 305g	Scale 1:1
					Hydrotech	
Zone	Revision note		Date	Signature		
Drawn			Audit			
Checked			Approved			